

Windload Charts |TD400 Series

 $\begin{array}{l} \mathsf{A} = 16 \ \mathsf{P.S.F.} (766 \ \mathsf{Pa}) \\ \mathsf{B} = 20 \ \mathsf{P.S.F.} (958 \ \mathsf{Pa}) \\ \mathsf{C} = 25 \ \mathsf{P.S.F.} (1197 \ \mathsf{Pa}) \\ \mathsf{D} = 30 \ \mathsf{P.S.F.} (1436 \ \mathsf{Pa}) \\ \mathsf{E} = 40 \ \mathsf{P.S.F.} (1915 \ \mathsf{Pa}) \end{array} \begin{array}{l} \mathsf{Description: Terrace Door} \\ \mathsf{Function: Entrances} \\ \mathsf{Detail: Design Criteria} \\ \mathsf{Scale: N.T.S.} \end{array}$

SHEET 1 OF 1



(2) 10020117 100202

- Mullions are assumed to be single span, simple beam elements, uniformly loaded and adequately braced to prevent lateral-torsional buckling. All other complex design conditions shall be reviewed by Arcadia or a design professional.
- Aluminum extrusions shall be 6063-T6 alloy. Allowable stresses to be derived per Aluminum Design Manual. Deflection limitation of mullions shall be in accordance with AAMA TIR-A11 of L/175 for spans up to 13-6" and L/240 + 1/4" for all others where L is equal to the span of mullion.
- A design professional shall be consulted to confirm that no lite of glass deflects more than H/175 or 3/4", whichever is less, where H indicates the height of glass.
- For mullions containing steel reinforcement, the reinforcement is assumed to be installed for the full length of the mullion. A design professional shall be consulted for instances where steel reinforcement is installed for a partial length of the mullion span.
- Windload pressure determinations shall be per ASCE 7 and according to local governing codes. A professional engineer shall be consulted for the most current laws and local building codes.
- Selection of perimeter fasteners and attachment of glazing system to building structure are project specific and therefore shall be reviewed and determined by a design professional.
- Arcadia assumes no responsibility for selecting the appropriate systems for specific projects.