





Windload Charts | IP2550 Series

A = 16 P.S.F. (766 Pa) Description: 2 1/2" X 5" Center Glazed For 9/16" Glass
 B = 20 P.S.F. (958 Pa) Function: Window Wall Impact System (Dry Glazed)
 C = 25 P.S.F. (1197 Pa) Detail: Design Criteria
 D = 30 P.S.F. (1436 Pa) Scale: N.T.S.
 E = 40 P.S.F. (1915 Pa) SHEET 1 OF 1




$$I = 6.038 \text{ IN}^4$$


$$S_1 = 2.406 \text{ IN}^3 \quad S_2 = 0.409 \text{ IN}^3$$



IP502 / IP510




$$I = 13.787 \text{ IN}^4$$




IP502 / IP510 WITH
STEEL REINFORCEMENT
1 7/16" X 4 5/8" X 10 GA.

- Mullions are assumed to be single span, simple beam elements, uniformly loaded and adequately braced to prevent lateral-torsional buckling. All other complex design conditions shall be reviewed by Arcadia or a design professional.
- Aluminum extrusions shall be 6063-T6 alloy. Allowable stresses to be derived per Aluminum Design Manual. Deflection limitation of mullions shall be in accordance with AAMA TIR-A11 of L/175 for spans up to 13'-6" and L/240 + 1/4" for all others where L is equal to the span of mullion.
- A design professional shall be consulted to confirm that no lite of glass deflects more than H/175 or 3/4", whichever is less, where H indicates the height of glass.
- For mullions containing steel reinforcement, the reinforcement is assumed to be installed for the full length of the mullion. A design professional shall be consulted for instances where steel reinforcement is installed for a partial length of the mullion span.
- Windload pressure determinations shall be per ASCE 7 and according to local governing codes. A professional engineer shall be consulted for the most current laws and local building codes.
- Selection of perimeter fasteners and attachment of glazing system to building structure are project specific and therefore shall be reviewed and determined by a design professional.
- Arcadia assumes no responsibility for selecting the appropriate systems for specific projects.



$$I = 5.965 \text{ IN}^4$$

$$S_1 = 2.042 \text{ IN}^3 \quad S_2 = 0.409 \text{ IN}^3$$



IP525 / IP5110

Consult Your Local Arcadia Representative For Special Applications Not Covered By These Curves.