




B = 20 P.S.F. (958 Pa) Function: Curtain Wall

C = 25 P.S.F. (1197 Pa) Detail: Design Criteria

D = 30 P.S.F. (1436 Pa)

E = 40 P.S.F. (1915 Pa) Scale: N.T.S.

SHEET 1 OF 1



- Mullions are assumed to be single span, simple beam elements, uniformly loaded and adequately braced to prevent lateral-torsional buckling. All other complex design conditions shall • be reviewed by Arcadia or a design professional.
- Aluminum extrusions shall be 6063-T6 alloy. Allowable stresses to be derived per Aluminum Design Manual. Deflection limitation of mullions shall be in accordance with AAMA TIR-A11 of L/175 for spans up to 13'-6" and L/240 + 1/4" for all others where L is equal to the span of mullion.
- A design professional shall be consulted to confirm that no lite of glass deflects more than H/175 or 3/4", whichever is less, where H indicates the height of glass
- For mullions containing steel reinforcement, the reinforcement is assumed to be installed for the full length of the mullion. A design professional shall be consulted for instances where steel reinforcement is installed for a partial length of the mullion span.
- Windload pressure determinations shall be per ASCE 7 and according to local governing codes. A professional engineer shall be consulted for the most current laws and local building codes.
- Selection of perimeter fasteners and attachment of glazing system to building structure are project specific and therefore shall be reviewed and determined by a design professional.
- Arcadia assumes no responsibility for selecting the appropriate systems for specific projects.




Deadload Charts T500 (OPG1900ET) Series Description: 2 1/4" X 7 3/4" With 1" Glass

Description: 2 1/4" X 7 3/4" With 1" Glas Function: Curtain Wall Detail: Design Criteria

Deadload Charts for 1" Glass Scale: N.T.S.

SHEET 1 OF 1





OPG1802 - 1" GLASS

